



Symbol	Tag	Qty	Label	Arrangement	Total Lamp Lumens	LLF	Description
⊙	AB1-T3-110W	5	UR20-56L-110-3K7-3-PT	Single	N.A.	0.750	UR20-56L-110-3K7-3-PT
⊙	AB5-T4	6	UR20-56L-110-4K7-4-PT	Single	N.A.	0.750	UR20-56L-110-4K7-4-PT
⊙	AB1 T3-BC	11	UR20-56L-75-3K7-3-BC-PT	Single	N.A.	0.750	UR20-56L-75-3K7-3-BC-PT
⊙	AA1 T5R	6	UR20-24L-25-3K7-5R-PT	Single	N.A.	0.750	UR20-24L-25-3K7-5R-PT
⊙	AB4 T3	8	UR20-56L-140-3K7-3-PT	Single	N.A.	0.750	UR20-56L-140-3K7-3-PT
⊙	ABS 20 T2	1	UR20-56L-140-3K7-2-PT	Single	N.A.	0.750	UR20-56L-140-3K7-2-PT

LPD Area Summary	Area	Total Watts	LPD
Label			

Label	CalcType	Units	Avg	Max	Min	Max/Min
Bus Drive Aisle	Illuminance	Fc	2.04	3.6	0.8	4.50
Bus Parking	Illuminance	Fc	2.24	3.6	1.0	3.60
Crosswalk-East	Illuminance	Fc	1.15	1.3	1.0	1.30
Crosswalk-East_1	Illuminance	Fc	1.71	2.2	1.1	2.00
Crosswalk-East_2	Illuminance	Fc	1.91	2.1	1.6	1.31
North Staff Lot Walkway	Illuminance	Fc	0.98	1.7	0.4	4.25
STAFF PARKING LOT	Illuminance	Fc	1.19	2.9	0.2	14.50
Van Drive Aisle	Illuminance	Fc	1.60	3.1	0.5	6.20
Van Parking	Illuminance	Fc	1.74	2.95	0.87	3.39
Walkways @ Facility East	Illuminance	Fc	1.43	2.8	0.4	7.00
zed	Illuminance	Fc	0.02	1.14	0.00	N.A.
zedd	Illuminance	Fc	0.03	1.30	0.00	N.A.



PROPOSED COMPROMISE SCHEME
 IsoFootcandle Plot of Lighting Performance
 with No Vehicles

Drawn By: ME
 Checked By: JPM
 Date: 12-7-2022

West Valley Transportation
 Parking Area