

PJR 078 | 3 - SEWAGE DISPOSAL

Mitigation Measures

None required.

Impact 3.15-3 Development under the Proposed Plan would not result in a determination by the wastewater treatment provider which serves or may serve the project that it does not have adequate capacity to serve the project's projected demand in addition to the provider's existing commitments. *(Less than Significant)*

A significant impact would occur if the SVCSD Treatment Plant would not have adequate capacity to serve the Proposed Plan's projected demand in addition to SVCSD's existing commitments. As shown in Table 3.15-2, at build-out, the Proposed Plan is estimated to generate about 0.3 MGd of wastewater, well within the treatment plant's existing capacity. SVCSD staff has confirmed for the projected build-out of the Proposed Plan that there will be sufficient capacity to serve buildout of the Proposed Plan in 2045. As a result, impacts will be less than significant.

Excerpted from Sonoma Developmental Center Specific Plan, Draft EIR

Section 3